

Test Report


Akku, 11.8.2016

Name: BOJAN ŠINKOVEC

Place of measurement: VELOG

Instruments: MK-2

Date: 11.8.2016



Measurement parameters

Sampling interval 15 second
Discharge current 25,0 A
Capacity 105,0 Ah
Charging time 0 hours
Discharge voltage 9,6 V
Acceptance level 60 %
100% Pass time 176 minutes

Results

1 Discharge 118 minutes
Measurement No. 1
Open circuit voltage 12,85 V
Measured Capacity 67 %
Measured Capacity 70,35 Ah
Qualification (Battery)

PASS

Comment, other: