

Test Report


Akku, 11.8.2016

Name: BOJAN ŠINKOVEC

Place of measurement: VELOG

Instruments: MK-2

Date: 11.8.2016



Measurement parameters

Sampling interval	15 second
Discharge current	25,0 A
Capacity	105,0 Ah
Charging time	0 hours
Discharge voltage	9,6 V
Acceptance level	60 %
100% Pass time	176 minutes

Results

1 Discharge 208 minutes
Measurement No. 1
Open circuit voltage 13,22 V
Measured Capacity 124 %
Measured Capacity 130,2 Ah
Qualification (Battery)

PASS

Comment, other