
Test Report Akku,12.8.2016

Name: BOJAN ŠINKOVEC

Place of measurement: VELOG

Instruments: MK-2

Date: 12.8.2016



Measurement parameters

Sampling interval
Discharge current
Capacity
Charging time
Discharge voltage
Acceptance level
100% Pass time

15 second
25,0 A
105,0 Ah
0 hours
9,6 V
400 %
176 minutes

Results

1 Discharge 141 minutes
Measurement No. 1
Open circuit voltage 13,02 V
Measured Capacity 80 %
Measured Capacity 86,4 Ah
Qualification (Battery)

PASS

Comment, other