

Test Report


Akku, 12.8.2016

Name: BOJAN ŠINKOVEC

Place of measurement: VELOG

Instruments: MK-2

Date: 12.8.2016



Measurement parameters

| | |
|-------------------|-------------|
| Sampling interval | 15 second |
| Discharge current | 25,0 A |
| Capacity | 105,0 Ah |
| Charging time | 0 hours |
| Discharge voltage | 9,6 V |
| Acceptance level | 60 % |
| 100% Pass time | 176 minutes |

Results

| | |
|-------------------------|-------------|
| 1 Discharge | 173 minutes |
| Measurement No. | 1 |
| Open circuit voltage | 13,12 V |
| Measured Capacity | 98 % |
| Measured Capacity | 102,9 Ah |
| Qualification (Battery) | |

PASS

Comment, other